

Table 3M-9. Annual Capacity, Energy Production, and Capacity Factor of Los Angeles Aqueduct Generating Facilities, by Subsystem, 1986-1990

	Owens River Gorge Subsystem	Owens Valley Subsystem	Aqueduct Subsystem
Capacity (MW)	110.0	9.0	81.0 <sup>a</sup>
Energy (GWh)			
1986	542.0	91.7	614.8
1987	409.1	59.6	561.1
1988	322.1	48.9	490.4
1989	288.4	46.6	382.2
1990	121.5	26.8	144.6
Capacity factor (%)			
1986	56.2	116.3	91.1
1987	42.5	75.6	79.6
1988	33.4	62.0	69.1
1989	29.9	59.1	53.9
1990	12.6	34.0	20.4

<sup>a</sup> In 1986, capacity was 77.0 MW.

Source: Singley and Neudeck pers. comms.